



NOTES:

1. The paved apron shall be a 2-1/2 inch minimum depth HMA or approved equivalent. Radius shall be 30 feet minimum and the length of pavement from the road edge shall be 20 feet.
2. Culvert installation shall be as shown on Drawing 508.D-1. The Revocable Encroachment Permit will specify the size of the culvert, but will be no less than 12 inch diameter.
3. The paved apron shall have a minimum 1-foot wide compacted crushed surfacing top course shoulder for 18-foot traveled way.
4. The paved apron shall have a minimum 1-foot wide compacted crushed surfacing top course shoulder for 20-foot traveled way.
5. The edge of the existing pavement shall be saw cut and sealed per Section 512.F.

DRAWING 505.E-4
PAVED APRON ON RESIDENTIAL URBAN PRIVATE STREET DETAIL
WHATCOM COUNTY DEPARTMENT OF PUBLIC WORKS